



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code 68-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title Indiana Residential Code		Edition 2009
Section number and title E4301.3		Page 725
Proponent Charlie Eldridge	Title Consultant	
Address 551 Grassy Ln., Indianapolis, IN 46217		Phone (317) 370-3444
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Add a new SECTION E4301.3 to the end of SECTION E4301 to read as follows: E4201.3 Spread of fire or products of combustion. The accessible portion of abandoned Class 2 cables shall not be permitted to remain.		
REASON AND FISCAL IMPACT		
This text was extracted from the 2005 Indiana Residential Code.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		